



**THE ADMINISTRATION OF UNION TERRITORY OF LADAKH**  
**OFFICE OF THE DIRECTOR FIRE AND EMERGENCY SERVICES UT LADAKH**

(e-mail-igp-ladakh@police.ladakh.gov.in)

(Office Phone No.01982-260888)

No: - PHQ/Dir/F&ES/UTL/2021-140-41

Dated:- 11/1/2021

**Subject: Fire NOC in favor of Army Good Will High School Harak Bahadur, Kargil.**

The report has been submitted by Superintendent of Police Fire and Emergency Services, Ladakh regarding the inspection of the instant school where in the spot visit was conducted by I/C F&ES Kargil. The detailed report of School building is as under:

**Location/Accessibility:**

The School is constructed at Harka Bahadur, Kargil. It is located at Longitude 76.107532 and Latitude 34.547689. The site is approximately 5 Kms away from Fire and Emergency Services Station, Kargil and it takes approximately 08 minutes to reach the site which is approachable for fire appliances.

**Detail of building:**

The School building has 10 blocks. There are three rooms in each block along with one room for Principal office block. There are 27 rooms and one hall in the all blocks. There are two windows in each class room and 4 windows in hall. The size of each window is 4x4 Ft. The height of the window from ground level is 4 feet. The two sides of each window has provision to open.

**The following Fire Safety equipment's found installed in School Building:**


1. The main gate size is 14 feet sufficient for the fire Tender to enter the premises in case of emergency.
2. 06 number of fire extinguishers ABC type 5 kg capacity, 02 number of CO2 type fire extinguishers 4.5 kg capacity and 02 number of DCP type fire extinguishers 25 kg capacity found installed in the school building.

**FIRE NOC is given in favor of Army Good Will High School Harak Bahadur, Kargil** for a period of **One year** from the issuance of this letter provided the school administration places 6 sand buckets in school premises and constructs at least 20 thousand liters of water tank before it is allowed to open keeping in view the COVID situation.

  
Director, F&ES, Ladakh  
PHQ, Agaling, Leh

**Copy to:**

1. Principal, Army Good Will High School Harak Bahadur, Kargil for information and n/a
2. Superintendent of Police, F&ES, Ladakh for information and with the direction to direct DFO, F&ES Leh for ensuring time bound installation of 6 sand buckets in school premises and construction of at least 20 thousand liters of water tank and this office be accordingly intimated.

  
ल० कर्नल/मैजर Lt Col/Maj  
उप कमान अधिकारी  
Second-in-Command  
31 वी बटालियन दि राजपूत रेजीमेन्ट  
31<sup>st</sup>Bn The Rajput Regiment